



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 06/17/25 at 09:53 AM
by Josh Bucknall
Account: 9626
Dakota Read Mix - DRM Inc.

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Sturgis ₁		06/17/25 09:00 AM	Absent	Absent		JMH 06/17/25	20250617807

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Pistan

REPORT APPROVED DATE: 6/18/2025 10:30:41 AM

DATE PRINTED: 06/18/2025 10:32 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 06/16/25 at 10:00 AM
by System Account
Account: 9626
Dakota Read Mix - DRM Inc.

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Sturgis ₁		06/16/25 09:00 AM	Absent	Absent		JMR 06/16/25	20250616801

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Disten

REPORT APPROVED DATE: 6/18/2025 8:36:56 AM

DATE PRINTED: 06/18/2025 08:42 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Received: 05/29/25 at 10:38 AM
by Josh Bucknall
Account: 9626
DRM Inc.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RANEY KOCH
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Temp Water ₁	#1	05/29/25 08:50 AM	Absent	Absent		JMH 05/29/25	20250529807
	Silver St. - Temp Water ₁	#2	05/29/25 08:53 AM	Absent	Absent		JMH 05/29/2025	20250529808

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Pistau

REPORT APPROVED DATE: 5/30/2025 11:58:34 AM

DATE PRINTED: 05/30/2025 12:03 PM

Review Data | SDWARS

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	200.7	lithium	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	11Cl- PF3OUdS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	4:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	6:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	8:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	9Cl- PF3ONS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	ADONA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	HFPO-DA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	NFDHA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFBA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFBS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFDA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFDaA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFEESA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHpA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHpS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHxA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHxS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFMBA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFMPA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFNA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFOA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFOS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFPeA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFPeS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFUnA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	NEtFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	PFTA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	PFTTrDA	< MRL	PWS/EPA Approved



MIDCONTINENT
TESTING LABORATORIES, INC.

2221 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/26/25 at 11:50 AM
by Josh Bucknall
Account: 9947
Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Well 8 FH North & South Run ₁		03/26/25 09:45 AM	Absent	Absent		JMH 03/26/2025	20250326820

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 3/27/2025 3:26:42 PM

DATE PRINTED: 03/27/2025 03:33 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2204 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/27/25 at 10:28 AM
by Josh Bucknall
Account: 9947
Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Well 8 North Line ₁		03/27/25 09:09 AM	Absent	Absent		JMH 03/27/2025	20250327812
	Well 8 South Line ₁		03/27/25 08:36 AM	Absent	Absent		JMH 03/27/2025	20250327813

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 3/28/2025 2:32:11 PM

DATE PRINTED: 03/28/2025 02:38 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Water Shop (2901
Vanocker Canyon Rd)
Sampled: 06/10/25 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250610829
Received: 06/10/25 at 10:15 AM
by Josh Bucknall
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.219	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 06/13/25
Field Test							
Field Fluoride	0.480	mg/L	1			Field Fluoride	JMH 06/11/25

Approved By:

Steve Pistan

Approved On: 6/16/2025 10:22:09 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

Sample Site: City Waterman (1055
Dudley St.)
Sampled: 06/03/25 at 09:08 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample
Matrix: Water

Lab ID#: 20250603941
Received: 06/03/25 at 11:00 AM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metals							
Fluoride	0.828	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 06/09/25
Field Test							
Field Fluoride	1.05	mg/L	1			Field Fluoride	JMH 06/04/25

Approved By: Steve Disten

Approved On: 6/11/2025 8:44:26 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Ford Regulator (2418 Junction)
Sampled: 05/12/25 at 07:20 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250512811
Received: 05/12/25 at 09:00 AM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.687	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 05/14/25
Field Test							
Field Fluoride	0.550	mg/L	1			Field Fluoride	JMH 05/13/25

Approved By:

Steve Pistau

Approved On: 5/15/2025 10:27:31 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

891 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Speedy Lube (2205 Park Ave)
Sampled: 05/05/25 at 07:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250505915
Received: 05/05/25 at 09:00 AM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.731	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 05/06/25
Field Test							
Field Fluoride	0.840	mg/L	1			Field Fluoride	JMH 05/06/25

Approved By: Steve Pistau

Approved On: 5/7/2025 11:32:21 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Regional Health
(2100 Davenport)
Sampled: 04/14/25 at 07:30 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250414811
Received: 04/14/25 at 09:30 AM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.692	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 04/15/25
Field Test							
Field Fluoride	0.950	mg/L	1			Field Fluoride	JMH 04/15/25

Approved By:

Steve Piston

Approved On: 4/16/2025 2:02:01 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 04/01/25 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250401817
Received: 04/01/25 at 10:11 AM
by Josh Bucknall
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.777	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 04/07/25
Field Test							
Field Fluoride	0.800	mg/L	1			Field Fluoride	JMH 04/02/25

Approved By: Steve Disten

Approved On: 4/8/2025 9:52:43 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 03/11/25 at 07:50 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water
Lab ID#: 20250311833
Received: 03/11/25 at 10:30 AM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.709	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 03/15/25
Field Test							
Field Fluoride	0.940	mg/L	1			Field Fluoride	JMH 03/12/25

Approved By: _____

Steve Ristan

Approved On: 3/17/2025 10:02:18 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Rasmussen Mech. Services
(3590 Mayor Ave)
Sampled: 03/05/25 at 07:50 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250305830
Received: 03/05/25 at 01:00 PM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.784	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 03/06/25
Field Test							
Field Fluoride	0.970	mg/L	1			Field Fluoride	JMH 03/06/25

Approved By:

Steve Pistan

Approved On: 3/7/2025 1:59:13 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Scott Peterson Motors
Sampled: 01/22/25 at 07:00 AM
by Russ Abernathy

Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250122813
Received: 01/22/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.301	mg/L	1	0.004	0.050	SM 4500 F-C	DVA 01/24/25
Field Test							
Field Fluoride	0.370	mg/L	1			Field Fluoride	JMH 01/23/25

Approved By: Steve Piston

Approved On: 1/24/2025 3:01:06 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Community Center (1401
Lazelle)

Sampled: 02/04/25 at 07:07 AM
by Brant Ager

Purpose: Routine

EPA
Number: 0321

Sturgis

Sample
Matrix: Water

Lab ID#: 20250204923

Received: 02/04/25 at 09:15 AM
by Jennifer Hill

Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.808	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 02/07/25
Field Test							
Field Fluoride	1.18	mg/L	1			Field Fluoride	JMH 02/05/25

Approved By:

Steve Disten

Approved On: 2/11/2025 10:50:12 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Scott Peterson Motors
Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 01/22/25 at 07:00 AM
by Russ Abernathy

Sample Matrix: Water

Lab ID#: 20250122813
Received: 01/22/25 at 09:30 AM
by System Account

Account: 8392 - Sturgis Water
Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.301	mg/L	1	0.004	0.050	SM 4500 F-C	DVA 01/24/25
Field Test							
Field Fluoride	0.370	mg/L	1			Field Fluoride	JMH 01/23/25

Report Approved By:

Steve Distau

Report Approved On: 1/24/2025 3:01:06 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Page 1 of 1

2221 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 — www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 01/14/25 at 07:30 AM
by R. Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water
Lab ID#: 20250114853
Received: 01/14/25 at 03:00 PM
by System Account
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.814	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 01/15/25
Field Test							
Field Fluoride	1.70	mg/L	1			Field Fluoride	SYS 01/15/25

Approved By: _____

Steve Ristan

Approved On: 1/15/2025 4:15:06 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 06/10/25 at 10:13 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		06/10/2025 07:20 AM	Absent	Absent	0.41 mg/L		JMH 06/10/2025	20250610807
0321	011	Sturgis Physical Therapy (1530 Junction)		06/10/2025 08:35 AM	Absent	Absent	0.39 mg/L		JMH 06/10/2025	20250610808
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		06/10/2025 06:45 AM	Absent	Absent	0.4 mg/L		JMH 06/10/2025	20250610809
0321	016	Scott Peterson Motors		06/10/2025 08:10 AM	Absent	Absent	0.53 mg/L		JMH 06/10/2025	20250610810

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 6/12/2025 9:34:31 AM

DATE PRINTED: 06/12/2025 09:55 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 06/03/25 at 11:00 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		06/03/2025 09:10 AM	Absent	Absent	0.69 mg/L		JMH 06/03/2025	20250603841
0321	006	Butte Ridge Building E (1900 Ellen St.)		06/03/2025 09:30 AM	Absent	Absent	0.51 mg/L		JMH 06/03/2025	20250603842
0321	015	City Public Works Shop (1870 Ballpark Rd)		06/03/2025 08:30 AM	Absent	Absent	0.75 mg/L		JMH 06/03/2025	20250603843
0321	020	Liberty Chevrolet		06/03/2025 08:14 AM	Absent	Absent	0.88 mg/L		JMH 06/03/2025	20250603844

REPORT APPROVED BY:

Steve Disten

REPORT APPROVED DATE: 6/5/2025 3:12:36 PM

DATE PRINTED: 06/05/2025 03:26 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

27 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/12/25 at 09:00 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		05/12/2025 06:45 AM	Absent	Absent	0.48 mg/L		JMH 05/12/2025	20250512804
0321	009	Loftus Dental Office (866 Lazelle)		05/12/2025 08:15 AM	Absent	Absent	0.43 mg/L		JMH 05/12/2025	20250512805
0321	014	Ford Regulator (2418 Junction)		05/12/2025 07:20 AM	Absent	Absent	0.39 mg/L		JMH 05/12/2025	20250512806
0321	019	Heritage Acres Bldg #2		05/12/2025 07:00 AM	Absent	Absent	0.45 mg/L		JMH 05/12/2025	20250512807

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 5/14/2025 1:38:43 PM

DATE PRINTED: 05/14/2025 02:03 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/05/25 at 09:00 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
321	003	Speedy Lube (2205 Park Ave)		05/05/2025 07:45 AM	Absent	Absent	0.57 mg/L		JMH 05/05/2025	20250505815
321	008	Sturgis City Hall (1040 Harley-Davidson Way)		05/05/2025 08:10 AM	Absent	Absent	48 mg/L		JMH 05/05/2025	20250505816
321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		05/05/2025 06:30 AM	Absent	Absent	0.44 mg/L		JMH 05/05/2025	20250505817
321	018	Little Promises University		05/05/2025 07:00 AM	Absent	Absent	0.55 mg/L		JMH 05/05/2025	20250505818

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 5/7/2025 9:38:12 AM

DATE PRINTED: 05/07/2025 09:59 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

22 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/14/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
321	007	Community Center (1401 Lazelle)		04/14/2025 06:50 AM	Absent	Absent	2.01 mg/L		JMR 04/14/2025	20250414805
321	012	Sturgis Regional Health (2100 Davenport)		04/14/2025 07:30 AM	Absent	Absent	0.63 mg/L		JMR 04/14/2025	20250414806
321	017	Northern Hills Vet Clinic		04/14/2025 08:10 AM	Absent	Absent	0.54 mg/L		JMR 04/14/2025	20250414807
321	020	Liberty Chevrolet		04/14/2025 08:35 AM	Absent	Absent	2.07 mg/L		JMR 04/14/2025	20250414808

REPORT APPROVED BY:

Steve Ristan

REPORT APPROVED DATE: 4/15/2025 2:50:33 PM

DATE PRINTED: 04/15/2025 02:55 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/01/25 at 10:11 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		04/01/2025 07:35 AM	Absent	Absent	0.78 mg/L		JMH 04/01/2025	20250401813
0321	016	Scott Peterson Motors		04/01/2025 12:00 AM	Absent	Absent	0.68 mg/L		JMH 04/01/2025	20250401814
0321	011	Sturgis Physical Therapy (1530 Junction)		04/01/2025 07:35 AM	Absent	Absent	0.49 mg/L		JMH 04/01/2025	20250401815
0321	016	Scott Peterson Motors		04/01/2025 08:05 AM	Absent	Absent	0.49 mg/L		JMH 04/01/2025	20250401816

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 4/2/2025 3:24:15 PM

DATE PRINTED: 04/02/2025 03:32 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

222 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/11/25 at 10:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		03/11/2025 06:30 AM	Absent	Absent	0.8 mg/L		JMH 03/11/2025	20250311808
0321	010	Schneider/Beckwith Dental (1245 Sherman)		03/11/2025 08:30 AM	Absent	Absent	0.72 mg/L		JMH 03/11/2025	20250311809
0321	015	City Public Works Shop (1870 Ballpark Rd)		03/11/2025 07:50 AM	Absent	Absent	0.66 mg/L		JMH 03/11/2025	20250311810
0321	020	Liberty Chevrolet		03/11/2025 07:06 AM	Absent	Absent	1.44 mg/L		JMH 03/11/2025	20250311811

REPORT APPROVED BY:

Steve Ristan

REPORT APPROVED DATE: 3/12/2025 2:55:06 PM

DATE PRINTED: 03/12/2025 03:07 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/05/25 at 01:00 PM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		03/05/2025 07:50 AM	Absent	Absent	0.83 mg/L		JMH 03/05/2025	20250305824
0321	009	Loftus Dental Office (866 Lazelle)		03/05/2025 08:15 AM	Absent	Absent	1.27 mg/L		JMH 03/05/2025	20250305825
0321	014	Ford Regulator (2418 Junction)		03/05/2025 07:15 AM	Absent	Absent	0.72 mg/L		JMH 03/05/2025	20250305826
0321	019	Heritage Acres Bldg #2		03/05/2025 07:00 AM	Absent	Absent	0.67 mg/L		JMH 03/05/2025	20250305827

REPORT APPROVED BY:

Steve Pistan

REPORT APPROVED DATE: 3/7/2025 1:59:13 PM

DATE PRINTED: 03/07/2025 02:13 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

22 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/10/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
321	003	Speedy Lube (2205 Park Ave)		02/10/2025 08:15 AM	Absent	Absent	0.57 mg/L		JMH 02/10/2025	20250210803
321	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/10/2025 08:45 AM	Absent	Absent	0.51 mg/L		JMH 02/10/2025	20250210804
321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		02/10/2025 06:45 AM	Absent	Absent	0.59 mg/L		JMH 02/10/2025	20250210805
321	018	Little Promises University		02/10/2025 07:30 AM	Absent	Absent	0.61 mg/L		JMH 02/10/2025	20250210806

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 2/12/2025 8:36:14 AM

DATE PRINTED: 02/12/2025 08:56 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

23rd South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/04/25 at 09:15 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
321	002	National Guard (701 14th St.)		02/04/2025 07:25 AM	Absent	Absent	0.54 mg/L		JMH 02/04/2025	20250204801
321	007	Community Center (1401 Lazelle)		02/04/2025 07:08 AM	Absent	Absent	0.58 mg/L		JMH 02/04/2025	20250204802
321	012	Sturgis Regional Health (2100 Davenport)		02/04/2025 08:04 AM	Absent	Absent	0.76 mg/L		JMH 02/04/2025	20250204803
321	017	Northern Hills Vet Clinic		02/04/2025 08:20 AM	Absent	Absent	0.68 mg/L		JMH 02/04/2025	20250204804

REPORT APPROVED BY:

Steve Disten

REPORT APPROVED DATE: 2/5/2025 3:53:19 PM

DATE PRINTED: 02/05/2025 04:05 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/22/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		01/22/2025 08:00 AM	Absent	Absent	0.64 mg/L		JMH 01/22/2025	20250122809
0321	006	Butte Ridge Building E (1900 Ellen St.)		01/22/2025 12:00 AM	Absent	Absent	0.74 mg/L		JMH 01/22/2025	20250122810
0321	011	Sturgis Physical Therapy (1530 Junction)		01/22/2025 08:45 AM	Absent	Absent	0.61 mg/L		JMH 01/22/2025	20250122811
0321	016	Scott Peterson Motors		01/22/2025 07:00 AM	Absent	Absent	0.54 mg/L		JMH 01/22/2025	20250122812

REPORT APPROVED BY:

Steve Disten

REPORT APPROVED DATE: 1/24/2025 9:17:18 AM

DATE PRINTED: 01/24/2025 09:23 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/14/25 at 12:00 PM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		01/14/2025 08:45 AM	Absent	Absent	0.64 mg/L		SAA 01/14/2025	20250114816
0321	010	Schneider/Beckwith Dental (1245 Sherman)		01/14/2025 08:30 AM	Absent	Absent	0.45 mg/L		SAA 01/14/2025	20250114817
0321	015	City Public Works Shop (1870 Ballpark Rd)		01/14/2025 07:30 AM	Absent	Absent	0.49 mg/L		SAA 01/14/2025	20250114818
0321	020	Liberty Chevrolet		01/14/2025 08:00 AM	Absent	Absent	0.74 mg/L		SAA 01/14/2025	20250114819

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 1/15/2025 4:15:06 PM

DATE PRINTED: 01/15/2025 04:25 PM