



DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

September 24, 2025

Mr. Todd Youngberg
City of Sturgis
1057 Dudley St
Sturgis, SD 57785

RE: Sturgis Public Water System (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample collected from **Sturgis Public Water System's** entry point on **September 8, 2025**, for the analysis of **nitrate**. The South Dakota Water Standards require that results of compliance monitoring be kept on file for not less than ten years.

The analytical results indicate that the nitrate sample from the entry point is below one-half the maximum contaminant level (MCL) of 10 mg/L. As a result, your system will continue to sample for nitrate on an annual basis. ***The next nitrate sample from your systems entry point will be due for analysis between January 1 and December 31, 2026.***

The nitrate and nitrite samples are "entry point" sampling; samples are to be collected at the entry point to the distribution system just after any treatment that may exist.

If you have questions concerning this letter or the nitrate results, please contact me.

Sincerely,

Peter Mockus
Drinking Water Program
(605) 773-4053



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

221 MALL DRIVE, SUITE #201
RAPID CITY SD 57701
danr.sd.gov

October 10, 2025

Mr. Todd Youngberg
City of Sturgis
1057 Dudley St
Sturgis, SD 57785

RE: Sturgis Public Water System (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received results of your Stage 2 Disinfection By-Products (DBP) sample dated September 08, 2025. The system is in compliance with the maximum contaminant levels for the Stage 2 DBP rule. The regulations require that the results of the compliance monitoring be kept on file for at least ten years.

The TTHM and HAA5 test results allow the system to remain on a reduced monitoring frequency. The system will be required to sample annually at the approved sampling location.

The approved sampling location is: Hydrant #15 – Dickson Road.

Your next DBP sample is due between August 1 and September 30, 2026.

Thank you for your interest in maintaining a safe water supply for your community. If you have any questions about this matter, please email or call me at my direct phone line listed below.

Sincerely,

Erin Fagnan
Drinking Water Program
(605) 910-4953



MIDCONTINENT
TESTING LABORATORIES, INC.

Received: 09/03/25 at 10:40 AM
by Josh Bucknall
Account: 8392
Sturgis Water Company

2221 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Avalanche Booster Station		09/03/25 06:35 AM	Absent	Absent		JMH 09/03/2025	20250903840

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 9/5/2025 3:11:44 PM

DATE PRINTED: 09/05/2025 03:22 PM



91 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Hyd @ N. end of Junction
Sampled: 09/08/25 at 07:00 AM
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250908901
Received: 09/08/25 at 09:30 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Volatile							
Bromodichloromethane	0.682	µg/L	1	0.004	0.500	EPA 524.2	KJW 09/16/25
Bromoform	< 0.500	µg/L	1	0.006	0.500	EPA 524.2	KJW 09/16/25
Chlorodibromomethane	1.04	µg/L	1	0.007	0.500	EPA 524.2	KJW 09/16/25
Chloroform	0.682	µg/L	1	0.018	0.500	EPA 524.2	KJW 09/16/25
Calculated Totals							
Total Haloacetic Acids	< 15.0	µg/L	1			EPA 552.2	SAC 09/19/25
Total Trihalomethanes	2.97	µg/L	1			EPA 524.2	KJW 09/16/25
Non-Volatile							
Dibromoacetic acid	< 2.50	µg/L	1			EPA 552.2	SAC 09/19/25
Dichloroacetic acid	< 2.50	µg/L	1			EPA 552.2	SAC 09/19/25
Monobromoacetic acid	< 2.50	µg/L	1			EPA 552.2	SAC 09/19/25
Monochloroacetic acid	< 5.00	µg/L	1			EPA 552.2	SAC 09/19/25
Trichloroacetic acid	< 2.50	µg/L	1			EPA 552.2	SAC 09/19/25

Approved By: Steve Ristan

Approved On: 10/3/2025 4:35:13 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Received: 09/30/25 at 11:35 AM
by Josh Bucknall
Account: 9947
Wilson Contracting, LLC

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	West Hydrant @ Avalanche1		09/30/25 11:10 AM	Absent	Absent		JMH 09/30/2025	20250930808

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/1/2025 2:17:06 PM

DATE PRINTED: 10/01/2025 02:22 PM



DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	West Hydrant @ Avalanche1		09/29/25 12:00 PM	Absent	Absent		JMH 09/29/2025	20250929840

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 9/30/2025 3:18:06 PM

DATE PRINTED: 09/30/2025 03:23 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Hydrant @ end of Orchard
Sampled: 09/17/25 at 09:20 AM by Wilson
Sample Matrix: Water

Lab ID#: 20250917805
Received: 09/17/25 at 09:44 AM by Josh Bucknall
Account: 9947 - Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	09/17/25
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	09/17/25
Field Test						
Field Chlorine	0.950	mg/L	1	Field Chlorine	JMH	09/18/25

Report Approved By: Steve Pistau

Report Approved On: 9/18/2025 2:24:30 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Orchard N Hydrant
Sampled: 09/18/25 at 09:13 AM
by Wilson
Sample Matrix: Water

Lab ID#: 20250918835
Received: 09/18/25 at 09:44 AM
by Josh Bucknall
Account: 9947 - Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	09/18/25
Total Coliform	Present		1	SM 9223 B (P/A)	JMH	09/18/25
Field Test						
Field Chlorine	0.660	mg/L	1	Field Chlorine	JMH	09/19/25

Report Approved By: Steve Pistau

Report Approved On: 9/22/2025 3:01:34 PM



MIDCONTINENT

TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Orchard N Hydrant
Sampled: 09/22/25 at 02:00 PM
Sample Matrix: Water

Lab ID#: 20250922819
Received: 09/22/25 at 02:30 PM
by System Account
Account: 9947 - Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

Parameter	Result	Units	DF	Method	Analyst/Date
Bacteria					
E. coli	Absent		1	SM 9223 B (P/A)	JMH 09/22/25
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH 09/22/25

Report Approved By: Steve Distau

Report Approved On: 9/24/2025 8:39:16 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Received: 08/11/25 at 02:08 PM
by Jennifer Hill
Account: 9844
Severson Dirt Works, LLC.

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

SEVERSON DIRT WORKS, LLC.
1455 SHORT TRACK RD.
STURGIS, SD 57785

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Sturgis Brown High School ₁	Football Field	08/11/25 01:00 PM	Absent	Absent		JMH 08/11/2025	20250811853

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 8/12/2025 3:46:48 PM

DATE PRINTED: 08/12/2025 03:48 PM

Review Data | SDWARS

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	200.7	lithium	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	11Cl- PF3OUdS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	4:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	6:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	8:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	9Cl- PF3ONS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	ADONA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	HFPO-DA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	NFDHA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFBA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFBS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFDA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFDoA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFEESA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFHpA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFHpS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFHxA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFHxS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFMBA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFMPA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFNA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFOA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFOS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFPeA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFPeS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	533	PFUnA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	537.1	NETFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	537.1	PFTA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE2	Eaton Analytical - Pomona	131573P	8/11/25	537.1	PFTTrDA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	200.7	lithium	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	11Cl-PF3OUdS	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	4:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	6:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	8:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	9CI-PF3ONS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	ADONA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	HFPO-DA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	NFDHA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFBA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFBS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFDA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFDoA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFEESA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHpA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHpS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHxA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHxS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFMBA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFMPA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFNA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFOA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFOS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFPeA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFPeS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFUnA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	NETFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	PFTA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	PFTrDA	< MRL	PWS/EPA Approved

Review Data | SDWARS

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	200.7	lithium	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	11Cl- PF3OUdS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	4:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	6:2 FTS	< MRL	PWS/EPA Approved
4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	8:2 FTS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	9Cl- PF3ONS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	ADONA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	HFPO-DA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	NFDHA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFBA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFBS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFDA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFDoA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFEESA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHpA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHpS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHxA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFHxS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFMBA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFMPA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFNA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFOA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFOS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFPeA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFPeS	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	533	PFUnA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	NEtFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	PFTA	< MRL	PWS/EPA Approved
SD4600321	10001	EP1	SE1	Eaton Analytical - Pomona	125936P	2/3/25	537.1	PFTTrDA	< MRL	PWS/EPA Approved



MIDCONTINENT
TESTING LABORATORIES, INC.

Received: 03/26/25 at 11:50 AM
by Josh Bucknall
Account: 9947
Wilson Contracting, LLC

2221 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Well 8 FH North & South Runj		03/26/25 09:45 AM	Absent	Absent		JMH 03/26/2025	20250326820

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/27/2025 3:26:42 PM

DATE PRINTED: 03/27/2025 03:33 PM

Received: 03/27/25 at 10:28 AM
by Josh Bucknall
Account: 9947
Wilson Contracting, LLC

2251 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Well 8 North Line ₁		03/27/25 09:09 AM	Absent	Absent		JMH 03/27/2025	20250327812
	Well 8 South Line ₁		03/27/25 08:36 AM	Absent	Absent		JMH 03/27/2025	20250327813

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/28/2025 2:32:11 PM

DATE PRINTED: 03/28/2025 02:38 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 07/17/25 at 01:06 PM
by Josh Bucknall
Account: 9626
Dakota Read Mix - DRM Inc.

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Install Main		07/17/25 12:32 PM	Absent	Absent		JMH 07/17/2025	20250717807

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

Notes:

youngberg@sturgisgov.com cmckillop@drmwyo.com

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/22/2025 2:00:43 PM

DATE PRINTED: 07/22/2025 02:09 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 07/17/25 at 02:30 PM
by System Account
Account: 9626
Dakota Read Mix - DRM Inc.

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Sturgis		07/16/25 01:18 PM	Absent	Absent		JMH 07/16/2025	20250716857

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/17/2025 3:01:22 PM

DATE PRINTED: 07/17/2025 03:10 PM

Received: 07/02/25 at 09:24 AM
by Josh Bucknall
Account: 9626
Dakota Read Mix - DRM Inc.

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Sturgis ₁	2nd Side of Street	07/02/25 08:36 AM	Absent	Absent		JMH 07/02/2025	20250702841
	Silver St. - Sturgis ₁	1st Side of Street	07/02/25 08:34 AM	Absent	Absent		JMH 07/02/2025	20250702842

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/3/2025 1:31:11 PM

DATE PRINTED: 07/03/2025 01:43 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Received: 06/17/25 at 09:53 AM
by Josh Bucknall
Account: 9626
Dakota Read Mix - DRM Inc.

2 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Sturgis ₁		06/17/25 09:00 AM	Absent	Absent		JMH 06/17/25	20250617807

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 6/18/2025 10:30:41 AM

DATE PRINTED: 06/18/2025 10:32 AM

Received: 06/16/25 at 10:00 AM
by System Account
Account: 9626
Dakota Read Mix - DRM Inc.

27 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

ERIC MCKILLOP
DRM INC.
PO BOX 1002
GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Sturgis		06/16/25 09:00 AM	Absent	Absent		JMH: 06/16/25	20250616801

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 6/18/2025 8:36:56 AM

DATE PRINTED: 06/18/2025 08:42 AM

Received: 05/29/25 at 10:38 AM
 by Josh Bucknall
 Account: 9626
 DRM Inc.

2 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
 (605) 348-0111 -- www.thechemistrylab.com

RANEY KOCH
 DRM INC.
 PO BOX 1002
 GILLETTE, WY 82717

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Silver St. - Temp Water ₁	#1	05/29/25 08:50 AM	Absent	Absent		JMH 05/29/25	20250529807
	Silver St. - Temp Water ₁	#2	05/29/25 08:53 AM	Absent	Absent		JMH 05/29/2025	20250529808

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Ristan

REPORT APPROVED DATE: 5/30/2025 11:58:34 AM

DATE PRINTED: 05/30/2025 12:03 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)
Sampled: 12/15/25 at 06:15 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20251215818
Received: 12/15/25 at 09:30 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.692	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 12/19/25
Field Test							
Field Fluoride	0.910	mg/L	1			Field Fluoride	JMH 12/16/25

Approved By: Steve Distau

Approved On: 12/22/2025 8:58:10 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)
Sampled: 12/08/25 at 07:04 AM by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20251208849
Received: 12/08/25 at 12:04 PM by Josh Bucknall
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.735	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 12/09/25
Field Test							
Field Fluoride	0.810	mg/L	1			Field Fluoride	JMH 12/09/25

Approved By: Steve Distau

Approved On: 12/10/2025 9:39:36 AM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: **Northern Hills Vet Clinic**
Sampled: 11/18/25 at 08:30 AM
by Russ Abernathy

Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20251118825
Received: 11/18/25 at 10:00 AM
by Josh Bucknall

Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.619	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 11/24/25
Field Test							
Field Fluoride	0.760	mg/L	1			Field Fluoride	JMH 11/19/25

Approved By: Steve Ristan

Approved On: 11/24/2025 2:52:39 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 11/10/25 at 07:11 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321
Sample Matrix: Water
Lab ID#: 20251110846
Received: 11/10/25 at 09:30 AM
by System Account
Account: 8392

Sturgis

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.706	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 11/11/25
Field Test							
Field Fluoride	0.870	mg/L	1			Field Fluoride	JMH 11/11/25

Approved By: _____

Steve Distau

Approved On: 11/12/2025 9:40:46 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 10/14/25 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20251014871
Received: 10/14/25 at 10:31 AM
by Josh Bucknall
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.529	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 10/20/25
Field Test							
Field Fluoride	0.620	mg/L	1			Field Fluoride	JMH 10/15/25

Approved By: Steve Distau

Approved On: 10/21/2025 9:52:06 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Rasmussen Mech. Services
(3590 Mayor Ave)
Sampled: 10/06/25 at 08:24 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20251006853
Received: 10/06/25 at 10:08 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.707	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 10/15/25
Field Test							
Field Fluoride	0.180	mg/L	1			Field Fluoride	JMH 10/07/25

Approved By: Steve Distau

Approved On: 10/16/2025 10:00:38 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Speedy Lube (2205 Park Ave)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 09/08/25 at 08:34 AM
by Brant Ager
Sample Matrix: Water
Lab ID#: 20250908819
Received: 09/08/25 at 09:30 AM
by System Account
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.709	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 09/15/25
Field Test							
Field Fluoride	0.890	mg/L	1			Field Fluoride	JMH 09/09/25

Report Approved By: Steve Distau

Report Approved On: 9/16/2025 10:54:24 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Community Center
(1401 Lazelle)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 09/03/25 at 07:00 AM
by Russ Abernathy
Sample Matrix: Water
Lab ID#: 20250903892
Received: 09/03/25 at 10:40 AM
by Josh Bucknall
Account: 8392 - Sturgis Water
Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.742	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 09/08/25
Field Test							
Field Fluoride	0.860	mg/L	1			Field Fluoride	JMH 09/04/25

Report Approved By: Steve Pistan

Report Approved On: 9/8/2025 1:31:41 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 08/18/25 at 10:55 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250818859
Received: 08/18/25 at 12:26 PM
by Josh Bucknall
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.707	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 08/20/25
Field Test							
Field Fluoride	0.800	mg/L	1			Field Fluoride	JMH 08/19/25

Approved By: Steve Distau

Approved On: 8/21/2025 9:58:55 AM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 08/12/25 at 06:35 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250812873
Received: 08/12/25 at 09:20 AM
by Sarah Ahlers
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.635	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 08/13/25
Field Test							
Field Fluoride	0.940	mg/L	1			Field Fluoride	JMH 08/13/25

Approved By: Steve Pistau

Approved On: 8/14/2025 11:01:25 AM



2281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)
Sampled: 07/14/25 at 09:05 AM by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250714810
Received: 07/14/25 at 09:30 AM by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.220	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 07/17/25
Field Test							
Field Fluoride	0.550	mg/L	1			Field Fluoride	SYS 07/16/25

Approved By: Steve Pistan

Approved On: 7/22/2025 10:54:20 AM



2291 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis City Hall (1040 Harley-Davidson Way)
Sampled: 07/07/25 at 08:05 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250707893
Received: 07/07/25 at 10:09 AM
by Josh Bucknall
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.811	mg/L	1	0.004	0.050	SM 4500 F-C	ECH 07/09/25
Field Test							
Field Fluoride	0.830	mg/L	1			Field Fluoride	JMH 07/08/25

Approved By: Steve Distau

Approved On: 7/11/2025 9:54:21 AM



2231 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)
Sampled: 06/10/25 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250610829
Received: 06/10/25 at 10:15 AM
by Josh Bucknall
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.219	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 06/13/25
Field Test							
Field Fluoride	0.480	mg/L	1			Field Fluoride	JMH 06/11/25

Approved By: Steve Ristan

Approved On: 6/16/2025 10:22:09 AM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Waterman (1055 Dudley St.)
Sampled: 06/03/25 at 09:08 AM by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250603941
Received: 06/03/25 at 11:00 AM by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.828	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 06/09/25
Field Test							
Field Fluoride	1.05	mg/L	1			Field Fluoride	JMH 06/04/25

Approved By: Steve Distau

Approved On: 6/11/2025 8:44:26 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)
Sampled: 05/12/25 at 07:20 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250512811
Received: 05/12/25 at 09:00 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.687	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 05/14/25
Field Test							
Field Fluoride	0.550	mg/L	1			Field Fluoride	JMH 05/13/25

Approved By: Steve Ristau

Approved On: 5/15/2025 10:27:31 AM



2291 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Speedy Lube (2205 Park Ave)
Sampled: 05/05/25 at 07:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250505915
Received: 05/05/25 at 09:00 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.731	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 05/06/25
Field Test							
Field Fluoride	0.840	mg/L	1			Field Fluoride	JMH 05/06/25

Approved By: Steve Ristan

Approved On: 5/7/2025 11:32:21 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Regional Health (2100 Davenport)
Sampled: 04/14/25 at 07:30 AM by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250414811
Received: 04/14/25 at 09:30 AM by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.692	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 04/15/25
Field Test							
Field Fluoride	0.950	mg/L	1			Field Fluoride	JMH 04/15/25

Approved By: Steve Distau

Approved On: 4/16/2025 2:02:01 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 04/01/25 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321
Sample Matrix: Water
Lab ID#: 20250401817
Received: 04/01/25 at 10:11 AM
by Josh Bucknall
Account: 8392

Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.777	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 04/07/25
Field Test							
Field Fluoride	0.800	mg/L	1			Field Fluoride	JMH 04/02/25

Approved By: Steve Pistau

Approved On: 4/8/2025 9:52:43 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 03/11/25 at 07:50 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250311833
Received: 03/11/25 at 10:30 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.709	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 03/15/25
Field Test							
Field Fluoride	0.940	mg/L	1			Field Fluoride	JMH 03/12/25

Approved By: Steve Pistau

Approved On: 3/17/2025 10:02:18 AM



MIDCONTINENT

TESTING LABORATORIES, INC.

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Rasmussen Mech. Services
(3590 Mayor Ave)
Sampled: 03/05/25 at 07:50 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250305830
Received: 03/05/25 at 01:00 PM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.784	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 03/06/25
Field Test							
Field Fluoride	0.970	mg/L	1			Field Fluoride	JMH 03/06/25

Approved By: _____

Steve Pistan

Approved On: 3/7/2025 1:59:13 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: **Scott Peterson Motors**
Sampled: 01/22/25 at 07:00 AM
by Russ Abernathy

Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250122813
Received: 01/22/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.301	mg/L	1	0.004	0.050	SM 4500 F-C	DVA 01/24/25
Field Test							
Field Fluoride	0.370	mg/L	1			Field Fluoride	JMH 01/23/25

Approved By: Steve Pistau

Approved On: 1/24/2025 3:01:06 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401
Lazelle)

Sampled: 02/04/25 at 07:07 AM
by Brant Ager

Purpose: Routine

EPA
Number: 0321

Sturgis

Sample
Matrix: Water

Lab ID#: 20250204923

Received: 02/04/25 at 09:15 AM
by Jennifer Hill

Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.808	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 02/07/25
Field Test							
Field Fluoride	1.18	mg/L	1			Field Fluoride	JMH 02/05/25

Approved By: _____

Steve Distau

Approved On: 2/11/2025 10:50:12 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Scott Peterson Motors
Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 01/22/25 at 07:00 AM
by Russ Abernathy
Sample Matrix: Water

Lab ID#: 20250122813
Received: 01/22/25 at 09:30 AM
by System Account
Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.301	mg/L	1	0.004	0.050	SM 4500 F-C	DVA 01/24/25
Field Test							
Field Fluoride	0.370	mg/L	1			Field Fluoride	JMH 01/23/25

Report Approved By:

Steve Pistan

Report Approved On: 1/24/2025 3:01:06 PM



2321 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 01/14/25 at 07:30 AM
by R. Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20250114853
Received: 01/14/25 at 03:00 PM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.814	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 01/15/25
Field Test							
Field Fluoride	1.70	mg/L	1			Field Fluoride	SYS 01/15/25

Approved By: Steve Pistau

Approved On: 1/15/2025 4:15:06 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 12/15/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

27 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
1321	005	City Waterman (1055 Dudley St.)		12/15/2025 06:50 AM	Absent	Absent	0.58 mg/L		JMH 12/15/2025	20251215812
1321	007	Community Center (1401 Lazelle)		12/15/2025 06:40 AM	Absent	Absent	0.59 mg/L		JMH 12/15/2025	20251215813
1321	014	Ford Regulator (2418 Junction)		12/15/2025 06:15 AM	Absent	Absent	0.57 mg/L		JMH 12/15/2025	20251215814
1321	015	City Public Works Shop (1870 Ballpark Rd)		12/15/2025 06:30 AM	Absent	Absent	0.61 mg/L		JMH 12/15/2025	20251215815

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 12/16/2025 2:32:11 PM

DATE PRINTED: 12/16/2025 02:37 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/08/25 at 10:04 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		12/08/2025 08:54 AM	Absent	Absent	1.08 mg/L		JMH 12/08/2025	20251208811
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		12/08/2025 07:48 AM	Absent	Absent	0.67 mg/L		JMH 12/08/2025	20251208812
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		12/08/2025 06:55 AM	Absent	Absent	1.36 mg/L		JMH 12/08/2025	20251208813
0321	018	Little Promises University		12/08/2025 07:22 AM	Absent	Absent	0.55 mg/L		JMH 12/08/2025	20251208814

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 12/10/2025 9:39:36 AM

DATE PRINTED: 12/10/2025 10:03 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 11/18/25 at 10:00 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

2001 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		11/18/2025 08:00 AM	Absent	Absent	0.44 mg/L		JMH 11/18/2025	20251118821
0321	007	Community Center (1401 Lazelle)		11/18/2025 06:45 AM	Absent	Absent	0.56 mg/L		JMH 11/18/2025	20251118822
0321	012	Sturgis Regional Health (2100 Davenport)		11/18/2025 07:30 AM	Absent	Absent	0.52 mg/L		JMH 11/18/2025	20251118823
0321	017	Northern Hills Vet Clinic		11/18/2025 08:30 AM	Absent	Absent	0.39 mg/L		JMH 11/18/2025	20251118824

REPORT APPROVED BY: Steve Disten

REPORT APPROVED DATE: 11/19/2025 2:21:38 PM

DATE PRINTED: 11/19/2025 02:43 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 11/10/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

2700 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		11/10/2025 06:45 AM	Absent	Absent	0.64 mg/L		JMH 11/10/2025	20251110807
0321	006	Butte Ridge Building E (1900 Ellen St.)		11/10/2025 07:08 AM	Absent	Absent	0.63 mg/L		JMH 11/10/2025	20251110808
0321	011	Sturgis Physical Therapy (1530 Junction)		11/10/2025 08:25 AM	Absent	Absent	0.43 mg/L		JMH 11/10/2025	20251110809
0321	016	Scott Peterson Motors		11/10/2025 08:10 AM	Absent	Absent	0.42 mg/L		JMH 11/10/2025	20251110810

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 11/12/2025 9:40:46 AM

DATE PRINTED: 11/12/2025 10:53 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 10/14/25 at 10:30 AM
by Greg McDougall

Account: 8392
Sturgis Water Company

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		10/14/2025 06:30 AM	Absent	Absent	0.58 mg/L		JMH 10/14/2025	20251014821
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		10/14/2025 06:50 AM	Absent	Absent	0.48 mg/L		JMH 10/14/2025	20251014822
0321	015	City Public Works Shop (1870 Ballpark Rd)		10/14/2025 06:45 AM	Absent	Absent	0.55 mg/L		JMH 10/14/2025	20251014823
0321	020	Liberty Chevrolet		10/14/2025 07:55 AM	Absent	Absent	0.49 mg/L		JMH 10/14/2025	20251014824

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/16/2025 1:22:50 PM

DATE PRINTED: 10/16/2025 02:10 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/06/25 at 10:08 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		10/06/2025 08:15 AM	Absent	Absent	0.3 mg/L		JMH 10/06/2025	20251006817
0321	009	Loftus Dental Office (866 Lazelle)		10/06/2025 08:45 AM	Absent	Absent	0.68 mg/L		JMH 10/06/2025	20251006818
0321	014	Ford Regulator (2418 Junction)		10/06/2025 07:25 AM	Absent	Absent	0.68 mg/L		JMH 10/06/2025	20251006819
0321	019	Heritage Acres Bldg #2		10/06/2025 07:40 AM	Absent	Absent	0.7 mg/L		JMH 10/06/2025	20251006820

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/8/2025 8:32:38 AM

DATE PRINTED: 10/08/2025 08:50 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Speedy Lube (2205 Park Ave)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 09/08/25 at 08:35 AM
by Brant Ager
Sample Matrix: Water
Lab ID#: 20250908808
Received: 09/08/25 at 09:30 AM
by System Account
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	Method	Analyst/Date
Bacteria					
E. coli	Absent		1	SM 9223 B (P/A)	JMH 09/08/25
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH 09/08/25
Field Test					
Field Chlorine	0.690	mg/L	1	Field Chlorine	JMH 09/09/25

Report Approved By: Steve Pistau

Report Approved On: 9/10/2025 8:29:41 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis City Hall
(1040 Harley-Davidson Way)

Purpose: Routine
EPA Number: 0321

Sampled: 09/08/25 at 07:56 AM
by Brant Ager

Sample Matrix: Water

Lab ID#: 20250908809
Received: 09/08/25 at 09:30 AM
by System Account

Account: 8392 - Sturgis Water Company

Sturgis

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	09/08/25
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	09/08/25
Field Test						
Field Chlorine	0.780	mg/L	1	Field Chlorine	JMH	09/09/25

Report Approved By: _____

Steve Pistau

Report Approved On: 9/10/2025 8:29:41 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Water Shop
(2901 Vanocker Canyon Rd)
Sturgis
Purpose: Routine
EPA Number: 0321
Sampled: 09/08/25 at 07:26 AM
by Brant Ager
Sample Matrix: Water
Lab ID#: 20250908810
Received: 09/08/25 at 09:30 AM
by System Account
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	09/08/25
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	09/08/25
Field Test						
Field Chlorine	0.560	mg/L	1	Field Chlorine	JMH	09/09/25

Report Approved By: _____

Steve Distau

Report Approved On: 9/10/2025 8:29:41 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Little Promises University
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 09/08/25 at 08:20 AM
by Brant Ager
Sample Matrix: Water
Lab ID#: 20250908811
Received: 09/08/25 at 09:30 AM
by System Account
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	09/08/25
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	09/08/25
Field Test						
Field Chlorine	0.810	mg/L	1	Field Chlorine	JMH	09/09/25

Report Approved By: Steve Pistau

Report Approved On: 9/10/2025 8:29:41 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 09/03/25 at 10:40 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

2801 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		09/03/2025 09:10 AM	Absent	Absent	0.36 mg/L		JMH 09/03/2025	20250903836
0321	007	Community Center (1401 Lazelle)		09/03/2025 07:00 AM	Absent	Absent	0.57 mg/L		JMH 09/03/2025	20250903837
0321	012	Sturgis Regional Health (2100 Davenport)		09/03/2025 08:30 AM	Absent	Absent	0.44 mg/L		JMH 09/03/2025	20250903838
0321	017	Northern Hills Vet Clinic		09/03/2025 08:45 AM	Absent	Absent	0.42 mg/L		JMH 09/03/2025	20250903839

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 9/5/2025 3:11:44 PM

DATE PRINTED: 09/05/2025 03:22 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 08/18/25 at 12:26 PM
by Josh Bucknall

Account: 8392
Sturgis Water Company

201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		08/18/2025 10:20 AM	Absent	Absent	0.99 mg/L		JMH 08/18/2025	20250818810
0321	006	Butte Ridge Building E (1900 Ellen St.)		08/18/2025 10:55 AM	Absent	Absent	0.48 mg/L		JMH 08/18/2025	20250818811
0321	011	Sturgis Physical Therapy (1530 Junction)		08/18/2025 11:15 AM	Absent	Absent	0.53 mg/L		JMH 08/18/2025	20250818812
0321	016	Scott Peterson Motors		08/18/2025 10:00 AM	Absent	Absent	0.56 mg/L		JMH 08/18/2025	20250818813

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 8/19/2025 3:26:49 PM

DATE PRINTED: 08/19/2025 03:47 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 08/12/25 at 09:20 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

2701 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	020	Liberty Chevrolet		08/12/2025 08:00 AM	Absent	Absent	0.46 mg/L		JMH 08/12/2025	20250812801
0321	005	City Waterman (1055 Dudley St.)		08/12/2025 06:55 AM	Absent	Absent	0.57 mg/L		JMH 08/12/2025	20250812802
0321	010	Schneider/Beckwith Dental (1245 Sherman)		08/12/2025 08:20 AM	Absent	Absent	0.48 mg/L		JMH 08/12/2025	20250812803
0321	015	City Public Works Shop (1870 Ballpark Rd)		08/12/2025 06:35 AM	Absent	Absent	0.54 mg/L		JMH 08/12/2025	20250812804

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 8/14/2025 9:26:01 AM

DATE PRINTED: 08/14/2025 09:44 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/14/25 at 09:45 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		07/14/2025 07:35 AM	Absent	Absent	0.44 mg/L		JMH 07/14/2025	20250714804
0321	009	Loftus Dental Office (866 Lazelle)		07/14/2025 08:35 AM	Absent	Absent	0.64 mg/L		JMH 07/14/2025	20250714805
0321	014	Ford Regulator (2418 Junction)		07/14/2025 09:05 AM	Absent	Absent	0.73 mg/L		JMH 07/14/2025	20250714806
0321	019	Heritage Acres Bldg #2		07/14/2025 08:35 AM	Absent	Absent	0.72 mg/L		JMH 07/14/2025	20250714807

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

7/16/2025 9:48:25 AM

DATE PRINTED:

07/16/2025 09:57 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/07/25 at 10:09 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		07/07/2025 07:55 AM	Absent	Absent	0.7 mg/L		JMH 07/07/2025	20250707814
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		07/07/2025 08:05 AM	Absent	Absent	0.45 mg/L		JMH 07/07/2025	20250707815
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		07/07/2025 06:45 AM	Absent	Absent	0.45 mg/L		JMH 07/07/2025	20250707816
0321	018	Little Promises University		07/07/2025 07:20 AM	Absent	Absent	0.42 mg/L		JMH 07/07/2025	20250707817

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

7/9/2025 10:21:20 AM

DATE PRINTED:

07/09/2025 10:37 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 06/10/25 at 10:13 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		06/10/2025 07:20 AM	Absent	Absent	0.41 mg/L		JMH 06/10/2025	20250610807
0321	011	Sturgis Physical Therapy (1530 Junction)		06/10/2025 08:35 AM	Absent	Absent	0.39 mg/L		JMH 06/10/2025	20250610808
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		06/10/2025 06:45 AM	Absent	Absent	0.4 mg/L		JMH 06/10/2025	20250610809
0321	016	Scott Peterson Motors		06/10/2025 08:10 AM	Absent	Absent	0.53 mg/L		JMH 06/10/2025	20250610810

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 6/12/2025 9:34:31 AM

DATE PRINTED: 06/12/2025 09:55 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 06/03/25 at 11:00 AM

by System Account

Account: 8392

Sturgis Water Company

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
1321	005	City Waterman (1055 Dudley St.)		06/03/2025 09:10 AM	Absent	Absent	0.69 mg/L		JMH 06/03/2025	20250603841
1321	006	Butte Ridge Building E (1900 Ellen St.)		06/03/2025 09:30 AM	Absent	Absent	0.51 mg/L		JMH 06/03/2025	20250603842
1321	015	City Public Works Shop (1870 Ballpark Rd)		06/03/2025 08:30 AM	Absent	Absent	0.75 mg/L		JMH 06/03/2025	20250603843
1321	020	Liberty Chevrolet		06/03/2025 08:14 AM	Absent	Absent	0.88 mg/L		JMH 06/03/2025	20250603844

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

6/5/2025 3:12:36 PM

DATE PRINTED:

06/05/2025 03:26 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 05/12/25 at 09:00 AM
by System Account

Account: 8392
Sturgis Water Company

2701 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
1321	004	Rasmussen Mech. Services (3590 Mayor Ave)		05/12/2025 06:45 AM	Absent	Absent	0.48 mg/L		JMH 05/12/2025	20250512804
1321	009	Loftus Dental Office (866 Lazelle)		05/12/2025 08:15 AM	Absent	Absent	0.43 mg/L		JMH 05/12/2025	20250512805
1321	014	Ford Regulator (2418 Junction)		05/12/2025 07:20 AM	Absent	Absent	0.39 mg/L		JMH 05/12/2025	20250512806
1321	019	Heritage Acres Bldg #2		05/12/2025 07:00 AM	Absent	Absent	0.45 mg/L		JMH 05/12/2025	20250512807

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 5/14/2025 1:38:43 PM

DATE PRINTED: 05/14/2025 02:03 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2391 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/05/25 at 09:00 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		05/05/2025 07:45 AM	Absent	Absent	0.57 mg/L		JMH 05/05/2025	20250505815
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		05/05/2025 08:10 AM	Absent	Absent	48 mg/L		JMH 05/05/2025	20250505816
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		05/05/2025 06:30 AM	Absent	Absent	0.44 mg/L		JMH 05/05/2025	20250505817
0321	018	Little Promises University		05/05/2025 07:00 AM	Absent	Absent	0.55 mg/L		JMH 05/05/2025	20250505818

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 5/7/2025 9:38:12 AM

DATE PRINTED: 05/07/2025 09:59 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 04/14/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	007	Community Center (1401 Lazelle)		04/14/2025 06:50 AM	Absent	Absent	2.01 mg/L		JMH 04/14/2025	20250414805
0321	012	Sturgis Regional Health (2100 Davenport)		04/14/2025 07:30 AM	Absent	Absent	0.63 mg/L		JMH 04/14/2025	20250414806
0321	017	Northern Hills Vet Clinic		04/14/2025 08:10 AM	Absent	Absent	0.54 mg/L		JMH 04/14/2025	20250414807
0321	020	Liberty Chevrolet		04/14/2025 08:35 AM	Absent	Absent	2.07 mg/L		JMH 04/14/2025	20250414808

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/15/2025 2:50:33 PM

DATE PRINTED: 04/15/2025 02:55 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/01/25 at 10:11 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		04/01/2025 07:35 AM	Absent	Absent	0.78 mg/L		JMH 04/01/2025	20250401813
0321	016	Scott Peterson Motors		04/01/2025 12:00 AM	Absent	Absent	0.68 mg/L		JMH 04/01/2025	20250401814
0321	011	Sturgis Physical Therapy (1530 Junction)		04/01/2025 07:35 AM	Absent	Absent	0.49 mg/L		JMH 04/01/2025	20250401815
0321	016	Scott Peterson Motors		04/01/2025 08:05 AM	Absent	Absent	0.49 mg/L		JMH 04/01/2025	20250401816

REPORT APPROVED BY:

Steve Pistan

REPORT APPROVED DATE:

4/2/2025 3:24:15 PM

DATE PRINTED:

04/02/2025 03:32 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 03/11/25 at 10:30 AM
by System Account

Account: 8392
Sturgis Water Company

2224 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		03/11/2025 06:30 AM	Absent	Absent	0.8 mg/L		JMH 03/11/2025	20250311808
0321	010	Schneider/Beckwith Dental (1245 Sherman)		03/11/2025 08:30 AM	Absent	Absent	0.72 mg/L		JMH 03/11/2025	20250311809
0321	015	City Public Works Shop (1870 Ballpark Rd)		03/11/2025 07:50 AM	Absent	Absent	0.66 mg/L		JMH 03/11/2025	20250311810
0321	020	Liberty Chevrolet		03/11/2025 07:06 AM	Absent	Absent	1.44 mg/L		JMH 03/11/2025	20250311811

REPORT APPROVED BY: Steve Pistan

REPORT APPROVED DATE: 3/12/2025 2:55:06 PM

DATE PRINTED: 03/12/2025 03:07 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 03/05/25 at 01:00 PM
by System Account

Account: 8392
Sturgis Water Company

2700 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		03/05/2025 07:50 AM	Absent	Absent	0.83 mg/L		JMH 03/05/2025	20250305824
0321	009	Loftus Dental Office (866 Lazelle)		03/05/2025 08:15 AM	Absent	Absent	1.27 mg/L		JMH 03/05/2025	20250305825
0321	014	Ford Regulator (2418 Junction)		03/05/2025 07:15 AM	Absent	Absent	0.72 mg/L		JMH 03/05/2025	20250305826
0321	019	Heritage Acres Bldg #2		03/05/2025 07:00 AM	Absent	Absent	0.67 mg/L		JMH 03/05/2025	20250305827

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/7/2025 1:59:13 PM

DATE PRINTED: 03/07/2025 02:13 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2300 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/10/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
321	003	Speedy Lube (2205 Park Ave)		02/10/2025 08:15 AM	Absent	Absent	0.57 mg/L		JMH 02/10/2025	20250210803
321	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/10/2025 08:45 AM	Absent	Absent	0.51 mg/L		JMH 02/10/2025	20250210804
321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		02/10/2025 06:45 AM	Absent	Absent	0.59 mg/L		JMH 02/10/2025	20250210805
321	018	Little Promises University		02/10/2025 07:30 AM	Absent	Absent	0.61 mg/L		JMH 02/10/2025	20250210806

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 2/12/2025 8:36:14 AM

DATE PRINTED: 02/12/2025 08:56 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 02/04/25 at 09:15 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

2324 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		02/04/2025 07:25 AM	Absent	Absent	0.54 mg/L		JMH 02/04/2025	20250204801
0321	007	Community Center (1401 Lazelle)		02/04/2025 07:08 AM	Absent	Absent	0.58 mg/L		JMH 02/04/2025	20250204802
0321	012	Sturgis Regional Health (2100 Davenport)		02/04/2025 08:04 AM	Absent	Absent	0.76 mg/L		JMH 02/04/2025	20250204803
0321	017	Northern Hills Vet Clinic		02/04/2025 08:20 AM	Absent	Absent	0.68 mg/L		JMH 02/04/2025	20250204804

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 2/5/2025 3:53:19 PM

DATE PRINTED: 02/05/2025 04:05 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/22/25 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
1321	001	G&G Enterprises (2251 Park Ave)		01/22/2025 08:00 AM	Absent	Absent	0.64 mg/L		JMH 01/22/2025	20250122809
1321	008	Butte Ridge Building E (1900 Ellen St.)		01/22/2025 12:00 AM	Absent	Absent	0.74 mg/L		JMH 01/22/2025	20250122810
1321	011	Sturgis Physical Therapy (1530 Junction)		01/22/2025 08:45 AM	Absent	Absent	0.61 mg/L		JMH 01/22/2025	20250122811
1321	016	Scott Peterson Motors		01/22/2025 07:00 AM	Absent	Absent	0.54 mg/L		JMH 01/22/2025	20250122812

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/24/2025 9:17:18 AM

DATE PRINTED: 01/24/2025 09:23 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

Purpose: Routine

Received: 01/14/25 at 12:00 PM
by System Account

Account: 8392
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		01/14/2025 08:45 AM	Absent	Absent	0.64 mg/L		SAA 01/14/2025	20250114816
0321	010	Schneider/Beckwith Dental (1245 Sherman)		01/14/2025 09:30 AM	Absent	Absent	0.45 mg/L		SAA 01/14/2025	20250114817
0321	015	City Public Works Shop (1870 Ballpark Rd)		01/14/2025 07:30 AM	Absent	Absent	0.49 mg/L		SAA 01/14/2025	20250114818
0321	020	Liberty Chevrolet		01/14/2025 08:00 AM	Absent	Absent	0.74 mg/L		SAA 01/14/2025	20250114819

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/15/2025 4:15:06 PM

DATE PRINTED: 01/15/2025 04:25 PM