



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

MIKE RIKER
FOTH INFRASTRUCTURE & ENVIRONMENT, LLC
SUITE 200
510 1/2 9TH STREET
RAPID CITY, SD 57701

Sample Site: Well 8 - Sturgis
Sampled: 01/08/26 at 12:00 PM
by Michael Riker
Sample Matrix: Water

Lab ID#: 20260108838
Received: 01/08/26 at 01:13 PM
by System Account
Account: 10119 - Foth Infrastructure & Environment, LLC

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	01/08/26
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	01/08/26

Report Approved By: Steve Distau

Report Approved On: 1/12/2026 11:32:20 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

MIKE RIKER
FOTH INFRASTRUCTURE & ENVIRONMENT, LLC
SUITE 200
510 1/2 9TH STREET
RAPID CITY, SD 57701

Sample Site: Well 8 - Sturgis
Location: Low Pressure - FH across road
Sampled: 03/02/26 at 11:20 AM by RA
Sample Matrix: Water

Lab ID#: 20260302845
Received: 03/02/26 at 02:45 PM by Jennifer Hill
Account: 10119 - Foth Infrastructure & Environment, LLC

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	03/02/26
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	03/02/26
Field Test						
Field Chlorine	0.760	mg/L	1	Field Chlorine	JMH	03/03/26

Report Approved By: Steve Distau

Report Approved On: 3/4/2026 11:30:20 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/03/26 at 02:50 PM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Well #81	Low Zone - FH at Access Rd.	03/03/26 10:30 AM	Absent	Absent		JMH 03/03/2026	20260303891
	Well #81	Booster Zone - FH at Davenport	03/03/26 11:45 AM	Absent	Absent		JMH 03/03/2026	20260303892

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/4/2026 3:14:10 PM

DATE PRINTED: 03/04/2026 03:27 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Well 8 - Sturgis
Sampled: 08/24/25 at 10:00 AM
by Mike
Sample Matrix: Water

Lab ID#: 20250825823
Received: 08/25/25 at 08:42 AM
by System Account
Account: 10119
Foth Infrastructure & Environment, LLC

MIKE RIKER
FOTH INFRASTRUCTURE & ENVIRONMENT, LLC
SUITE 200
510 1/2 9TH STREET
RAPID CITY, SD 57701

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Metals - Total							
Iron (Fe)	0.082	mg/L	10	0.015	0.050	EPA 200.8	TNA 08/26/25
Bacteria							
E. coli	Absent		1			SM 9223 B (P/A)	JMH 08/25/25
Total Coliform	Absent		1			SM 9223 B (P/A)	JMH 08/25/25

Approved By: Steve Distau

Approved On: 8/28/2025 10:01:26 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: **Mark Archibald**
Sampled: 09/17/25 at 04:45 PM
by Will McCall
Sample Matrix: Water

Lab ID#: 20250918828
Received: 09/18/25 at 12:40 PM
by Josh Bucknall
Account: 10210
Keller Drilling, LLC.

KELLER DRILLING, LLC.
17876 110TH ST.
LEMMON, SD 57638

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Physical Properties								
Electrical Conductivity	1580	µmhos/cm	1	0.168	5.00	SM 2510B	JAM	09/19/25
Non-Metallics								
Nitrogen, Nitrate (NO3)	< 0.050	mg/L	1	0.009	0.050	SM 4500-NO3 F	BLL	09/19/25
Sulfate (SO4)	82.4	mg/L	2	0.601	20.0	SM 4500-SO4 E	BLL	09/19/25
Metals - Dissolved								
Sodium (Na)	420	mg/L	27	6.32	27.0	SM 3111 B	GRT	09/23/25
Bacteria								
E. coli	Absent		1			SM 9223 B (P/A)	JMH	09/18/25
Total Coliform	Present		1			SM 9223 B (P/A)	JMH	09/18/25

Approved By: Steve Distau

Approved On: 9/24/2025 10:30:32 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

MIKE RIKER
FOTH INFRASTRUCTURE & ENVIRONMENT, LLC
SUITE 200
510 1/2 9TH STREET
RAPID CITY, SD 57701

Sample Site: Well 8 - Sturgis
Sampled: 01/07/26 at 11:00 AM
by Mike Riker
Sample Matrix: Water

Lab ID#: 20260107832
Received: 01/07/26 at 11:54 AM
by Josh Bucknall
Account: 10119 - Foth Infrastructure & Environment, LLC

Parameter	Result	Units	DF	Method	Analyst/Date	
Bacteria						
E. coli	Absent		1	SM 9223 B (P/A)	JMH	01/07/26
Total Coliform	Absent		1	SM 9223 B (P/A)	JMH	01/07/26

Report Approved By: Steve Distau

Report Approved On: 1/8/2026 3:08:00 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/05/26 at 10:03 AM
by Jennifer Hill
Account: 9947
Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	NW Oakwood Fire Hydrant ₁		03/05/26 09:28 AM	Absent	Absent		JMH 03/05/2026	20260305811

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/6/2026 1:38:01 PM

DATE PRINTED: 03/06/2026 02:02 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/06/26 at 09:32 AM
by Sarah Ahlers
Account: 9947
Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	NW Oakwood Fire Hydrant ₁		03/06/26 09:00 AM	Absent	Absent		JMB 03/06/2026	20260306804

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/9/2026 10:15:33 AM

DATE PRINTED: 03/09/2026 10:21 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Public Works Shop
(1870 Ballpark Rd)
Sampled: 03/09/26 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20260309836
Received: 03/09/26 at 10:21 AM
by Sarah Ahlers
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.715	mg/L	1	0.003	0.050	SM 4500 F-C	IBS 03/12/26
Field Test							
Field Fluoride	0.830	mg/L	1			Field Fluoride	JMH 03/10/26

Approved By: Steve Distau

Approved On: 3/12/2026 3:58:06 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Heritage Acres Bldg #2
Sampled: 02/09/26 at 07:45 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20260209828
Received: 02/09/26 at 10:00 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.691	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 02/11/26

Approved By: Steve Pistor

Approved On: 2/16/2026 9:27:28 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis City Hall (1040 Harley-Davidson Way)
Sampled: 02/03/26 at 10:05 AM by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20260203889
Received: 02/04/26 at 11:15 AM by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.693	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 02/06/26
Field Test							
Field Fluoride	0.710	mg/L	1			Field Fluoride	JMH 02/04/26

Approved By: Steve Pistau

Approved On: 2/6/2026 2:49:07 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401
Lazelle)

Sampled: 01/20/26 at 06:20 AM
by Russ Abernathy

Purpose: Routine

EPA
Number: 0321

Sturgis

Sample
Matrix: Water

Lab ID#: 20260120850
Received: 01/20/26 at 09:22 AM
by Josh Bucknall

Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.696	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 01/22/26
Field Test							
Field Fluoride	0.850	mg/L	1			Field Fluoride	JMH 01/21/26

Approved By: Steve Distau

Approved On: 1/22/2026 3:34:12 PM



South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Scott Peterson Motors
Sampled: 01/12/26 at 07:30 AM
by Russ Abernathy
EPA Number: 0321
Sturgis
Sample Matrix: Water

Lab ID#: 20260112827
Received: 01/12/26 at 12:00 PM
by System Account
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.675	mg/L	1	0.004	0.050	SM 4500 F-C	IBS 01/16/26
Field Test							
Field Fluoride	0.640	mg/L	1			Field Fluoride	SYS 01/12/26

Approved By: Steve Distau

Approved On: 1/20/2026 3:16:25 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/09/26 at 10:21 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	City Waterman (1055 Dudley St.)		03/09/2026 08:45 AM	Absent	Absent	0.25 mg/L		JMH 03/09/2026	20260309808
0321	010	Schneider/Beckwith Dental (1245 Sherman)		03/09/2026 08:20 AM	Absent	Absent	0.28 mg/L		JMH 03/09/2026	20260309809
0321	015	City Public Works Shop (1870 Ballpark Rd)		03/09/2026 06:45 AM	Absent	Absent	0.28 mg/L		JMH 03/09/2026	20260309810
0321	020	Liberty Chevrolet		03/09/2026 08:10 AM	Absent	Absent	0.26 mg/L		JMH 03/09/2026	20260309811

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/10/2026 3:07:02 PM

DATE PRINTED: 03/10/2026 03:13 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/09/26 at 11:00 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		02/09/2026 08:36 AM	Absent	Absent	0.48 mg/L		JMH 02/09/2026	20260209813
0321	009	Loftus Dental Office (866 Lazelle)		02/09/2026 08:54 AM	Absent	Absent	0.66 mg/L		JMH 02/09/2026	20260209814
0321	014	Ford Regulator (2418 Junction)		02/09/2026 07:28 AM	Absent	Absent	0.46 mg/L		JMH 02/09/2026	20260209815
0321	019	Heritage Acres Bldg #2		02/09/2026 07:41 AM	Absent	Absent	0.64 mg/L		JMH 02/09/2026	20260209816

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 2/11/2026 10:20:25 AM

DATE PRINTED: 02/11/2026 10:27 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/03/26 at 11:15 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		02/03/2026 09:10 AM	Absent	Absent	0.26 mg/L		JMH 02/03/2026	20260203831
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/03/2026 10:03 AM	Absent	Absent	0.37 mg/L		JMH 02/03/2026	20260203832
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		02/03/2026 09:40 AM	Absent	Absent	0.53 mg/L		JMH 02/03/2026	20260203833
0321	018	Little Promises University		02/03/2026 09:50 AM	Absent	Absent	0.54 mg/L		JMH 02/03/2026	20260203834

REPORT APPROVED BY: Steve Distan

REPORT APPROVED DATE: 2/5/2026 12:03:41 PM

DATE PRINTED: 02/05/2026 12:19 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/20/26 at 09:22 AM
by Josh Bucknall

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		01/20/2026 08:20 AM	Absent	Absent	0.6 mg/L		JMH 01/20/2026	20260120806
0321	007	Community Center (1401 Lazelle)		01/20/2026 06:20 AM	Absent	Absent	0.39 mg/L		JMH 01/20/2026	20260120807
0321	012	Sturgis Regional Health (2100 Davenport)		01/20/2026 07:45 AM	Absent	Absent	0.4 mg/L		JMH 01/20/2026	20260120808
0321	017	Northern Hills Vet Clinic		01/20/2026 08:05 AM	Absent	Absent	0.55 mg/L		JMH 01/20/2026	20260120809

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 1/22/2026 3:34:12 PM

DATE PRINTED: 01/22/2026 03:41 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/12/26 at 12:00 PM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	B&G Enterprises (2251 Park Ave)		01/12/2026 06:30 AM	Absent	Absent	0.53 mg/L		JMH 01/12/2026	20260112809
0321	006	Butte Ridge Building E (1900 Ellen St.)		01/12/2026 07:00 AM	Absent	Absent	0.48 mg/L		JMH 01/12/2026	20260112810
0321	011	Sturgis Physical Therapy (1530 Junction)		01/12/2026 08:15 AM	Absent	Absent	0.64 mg/L		JMH 01/12/2026	20260112811
0321	016	Scott Peterson Motors		01/12/2026 07:30 AM	Absent	Absent	0.54 mg/L		JMH 01/12/2026	20260112812

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/14/2026 9:05:15 AM

DATE PRINTED: 01/14/2026 09:27 AM