


PERIMETER SECTION SCHEDULE							
SECT NO	TYPE	DESCRIPTION			WEIR	JET	OTHER
		DIM. 'A'	DIM. 'B'	ANGLE 'C'			
1	III	10'-11"		45°			(1) RLA
2	STR	11'-11 1/2"					(2) RLA
3	STR	5'-5"					(2) RLA
4	STR	11'-11 1/2"					(2) RLA
5	II	10'-11"		45°	I-L		(2) RLA
6	III	10'-11"		45°			
7	STR	11'-11 1/2"					
8	STR	11'-11 1/2"					
9	STR	5'-7"					
10	STR	11'-11 1/2"					
11	STR	11'-11 1/2"					
12	II	10'-11"		45°	I-L	AAR	
13	III	10'-11"		45°			(1) RLA
14	STR	11'-11 1/2"					(2) RLA
15	STR	5'-7"					(2) RLA
16	STR	11'-11 1/2"					(2) RLA
17	STR	11'-11 1/2"					(2) RLA
18	STR	11'-11 1/2"					(2) RLA
19	II	10'-11"		45°			
20	III	10'-11"		45°	I-R		
21	STR	4'-0"					
22	STR	9'-2"					
23	II	10'-11"		45°			
24	III	10'-11"		45°			
25	STR	7'-4"					
26	I	11'-10"		45°			(1) LLA
27	IV	11'-10"		45°			
28	STR	4'-0"					
29	STR	8'-7"					
30	I	11'-10"		45°	8" P.O.	I-L	6" RTN
31	VI	6'-0"		45°		I-L	STEP COVER
32	VII	4'-0"		45°		I-R	STEP COVER

MATERIAL SCHEDULE	
STAINLESS STEEL TUBE # GLITTER-ASC-W	313'-0"
STAINLESS STEEL GUTTER	
ANCHOR ANGLES 1/2 X 1/2 X 3/16 X 11"	90
STIFFENER BRACKETS (SET OF 3) 2 1/2 X 1 1/4 X 1/2"	90
"U" BAR ANCHORS	90
NYLON INLET NOZZLES 9/16" O.D. I.D. 1/4"	115
0 RUBBER TEST PLUGS	115
SURGE WEIRS	9
JET WASH FITTINGS #9018-SL	9
JET WASH FITTING CAP 1/2" IPS (GABO) TEST ONLY	9
WATER AGITATOR FITTINGS	
LIFE LINE ANCHORS #9026	2
RACING LINE ANCHORS #9021 (3/8" DIA. PORT)	14
SCOTCH BRITE PADS	6
AUTO AIR RELEASE	
6" RETURN LINE CONNECTION SHIP LOOSE	1
6" GUTTER LINE CONNECTION NO CUTOUTS	1
STIFF. PL. # 5 1/2" CHANN./ANCHORS	16
1" X 13" LONG ALUMINUM GAUGE BAR	
STAINLESS STEEL GUTTER PANS	
#10-24 X 3/4" LG. ST. ST. P.H. PHIL. SCR.	110
3/4" X 3/4" X 8 1/2" LG. ST. ST. ANGLE @ CORNERS	16
9" X 9" MOLDED R/C GRATES (WHITE)	44
12 GA. ST. ST. STIFFENER @ BUTT JOINTS	24
12 GA. ST. ST. STEP COVER-1'-0" X 4'-0" X 1'-0"	1



- NOTES:
1. POOL DIMENSIONS ARE FROM FACE TO FACE OF TUBE.
 2. ■ DENOTES SURGE WEIRS.
 3. ▲ DENOTES JET WASH FITTINGS.
 4. ▲ DENOTES (2) EXTRA MATERIAL FOR FIELD CUT.
 5. # DENOTES DRILL & TAP TUBE 1/4" I.P.S. TO SUPPLY JET WASH FITTING IN PAN.
 6. ALL STAINLESS STEEL SHALL BE LOW CARBON TYPE 304 UNLESS OTHERWISE INDICATED.
 7. TOTAL RECIRCULATING RATE IS: 517 G.P.M.
 8. POOL PERIMETER IS: 312 FT. 4 IN.
 9. TYPE OF POOL CONSTRUCTION IS: CONCRETE
 10. POOL AREA IS: 4497 SQ. FT.
 11. POOL LOCATION IS: INDOORS
 12. TYPE OF RECIRCULATION SYSTEM: ASC-W, 14 GA-STANDARD CONFIGURATION

NO	CHANGED FOR	ADDED PER	D.G. OF	APSE	BY	DATE
3						
2						
1	CHANGED FOR	ADDED PER	D.G. OF	APSE	JTB	9-22-90

Paddock

FABRICATION DRAWING
STURGIS COMMUNITY CENTER
STURGIS

CONTRACTOR - BUILDER
ASSOCIATED SUPPLY CO.

PADDOCK POOL EQUIP. CO. INC.
 ROCK HILL, S.C. 29730

W.D. NO. P130915
 SCALE: 3/8" = 1'-0"
 DATE: 15 SEPT 90
 DRAWN BY: DJK
 REV. NO.
 DRAWING NO. 3114-1

21A

673