

SMOOTH CUT
ENDS OF PIPE

CONCRETE, STEEL
TROWEL FINISH

6" DIA. - 1/4" STEEL PIPE M6
FILL WITH CONCRETE AS SHOWN
(ASTM A120 STEEL PIPE, SCHEDULE 40)

PRIMER & PAINT YELLOW

3'-0"

* PROVIDE EXPANSION JOINT MATERIAL
WHEN ABUTTING P.C.C. PAVING

FINISHED GRADE

A.C.C.

*P.C.C.


POST TO BE SET IN M-6
CONCRETE AS SHOWN

4'-0"

3" MIN.
COVER



FIRE HYDRANT



3'-0" CLEAR



BOLLARD



CITY OF STURGIS STANDARD DETAILS

DATE: APRIL 2019

FIRE HYDRANT PROTECTION BOLLARD DETAIL

8-2